

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department
Annual Periodical Renewal Fire Certificate

From:
Regional Fire Officer
Andhra Pradesh, Vijayawada

To:
The District Educational Officer,
Machilipatnam, Krishna District

File No: 14873/KRI/RFO/2020, Date:24/11/2020
Occupancy NoC RC Number: 408/RFO/ER/2019

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of M/s Sri Srinivasa Aksharalayam, School, represented by Paruchuri Srinivasa Rao, D.NO: 7-374/7 & 7-378/8, Thotlavalluru, Vuyyuru - Regarding.

- Ref:
1. G.O.Ms.NO.71 Home (Prisons-A) Department, Dated.01-04-2010 & G.O.Ms.NO.140 Home(Prison & Fire Services) Department, Dt.04-09-2015.
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.09-03-2017.
 3. This Office NOC for Occupancy Rc No. 408/RFO/ER/2019, Dt.21/06/2019
 4. Renewal NOC For Occupancy 408/RFO/ER/2019, Dt.21/06/2019
 5. Online Application for Renewal NOC of Paruchuri Srinivasa Rao, D.NO: 7-374/7 & 7-378/8, Thotlavalluru, Vuyyuru - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 21-11-2020.

<< 0 >>

The Management of M/s Vidyaranya Educational Society, represented by Paruchuri Srinivasa Rao, D.NO: 7-374/7 & 7-378/8, Thotlavalluru, Vuyyuru has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs.182875/- vide challan No. 41195796962020, Dated 23/10/2020 at Online payment, Online payment.

Block I

,Block IV

,Block V

,Block VI


,Block VII

,Block VIII

,Block III

,Block II


MANAGER
Sri Srinivasa Aksharalayam (EM) School
T.V ROAD, VUY YURU, KRISHNA(DT)
ANDHRA PRADESH PIN - 521165.


PRINCIPAL
Sri Srinivasa Aksharalayam (EM) School
T.V ROAD, VUY YURU, KRISHNA (DT)
ANDHRA PRADESH PIN - 521165.

1. This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate **Paruchuri Srinivasa Rao D.NO: 7-374/7 & 7-378/8, Thotlavalluru, Vuyyuru**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

4. This Annual Periodical Renewal Fire Certificate is valid from 21/06/2020 to 20/06/2025.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

The following deficiencies are identified by the officers of the department and needs to be attended to by the management.

Recommended:

1. This Renewal NOC is issued from Fire Safety Point of view only basing on recommendation of the inspection Committee and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time.
2. This Renewal NOC is valid for Five years only and It is the responsibility of the Builder/Owner to apply for renewal of No Objection certificate, duly remitting the user charges as per G.O.Ms.No.169, Home (Prisons & Fire Service) Department. Dt. 19-12-2019. Two months before expire of this No Objection Certificate.
3. The occupier/Owner /Builder/Management concerned of the building premises, shall maintain the Fire Prevention and Fire Safety Measures provided by the building as per Occupancy NOC at all times for good use by the Occupant (or) Members of Fire Services (or) Both in the event of outbreak of Fire.
4. The Renewal NOC issued based on Inspection Committee report.



14873/KRI/RF0/2020

Your Sincerely,

[Signature]
Regional Fire Officer
Andhra Pradesh, Vijayawada

- Copy to Paruchuri Srinivasa Rao, D.NO: 7-374/7 & 7-378/8, Thotlavalluru, Vuyyuru
- Copy to Chief Office for Record Purpose
- Copy to District Fire Officer Concerned
- Copy to Assistant District Fire Officer Concerned
- Copy to Station Fire Officer Concerned

[Signature]
MANAGER

Sri Srinivasa Aksharayam (EM) School
T.V ROAD, VUYURU, KRISHNA (DT)
ANDHRA PRADESH PIN - 521165.

[Signature]
PRINCIPAL
Sri Srinivasa Aksharayam (EM) School
T.V ROAD, VUYURU, KRISHNA (DT)
ANDHRA PRADESH PIN - 521165.